

Completed By:

Location:

Date Completed:

### Protection from Falling Objects (Construction)

**Instructions:** This checklist is intended to help you identify potential hazards in your workplace. The questions are based on applicable Federal OSHA standards. Keep in mind that additional state and local regulations may apply, depending upon your location. Please check one answer for each question. If you select “no,” you should investigate further to determine what corrective action may be needed to address the hazard. You can review the specific OSHA Standards outlined below at [www.osha.gov/law-regs.html](http://www.osha.gov/law-regs.html). Choose “General Industry” or “Construction.”

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Protection from Falling Objects (Construction)</b>				
1)	Are toeboards a minimum of 3-1/2 inches in vertical height from their top edge to the level of the walking/working surface?	1926.452(a)(5)			
2)	Can toeboards withstand (without failure) a force of at least 50 pounds applied in any downward or outward direction at any point along the toeboard?	1926.452(a)(6)			
3)	During overhand bricklaying and related work, are materials or equipment stored at least 4 feet from the working edge?	1926.452(a)(7)			
4)	During roofing work, are materials and equipment stored at least 6 feet from a roof edge, unless guardrails are erected at the edge?	1926.452(a)(9)			
5)	During roofing work, are materials that are piled, grouped, or stacked near a roof edge stable and self-supporting?	1926.452(a)(2)			
6)	When guardrail systems are used as falling object protection, are openings small enough to prevent falling objects from passing through?	1926.452(a)(4)			
7)	When used as falling object protection, are toeboards erected along the edge of the overhead walking/working surface for a distance sufficient to protect workers below?	1926.452(a)(3)			
8)	Where tools, equipment, or materials are piled higher than the top edge of a toeboard, is paneling or screening erected from the walking/working surface or toeboard to the top of a guardrail system's top rail or midrail?	1926.452(a)(8)			

---

# Protection from Falling Objects (Construction)

---

**Safety Checklist Disclaimer:** This safety checklist (the "Material") is made available to the user or other receiver of the Material for general informational purposes only. The Material has been developed with consideration of various factors relevant to the subject area, including federal laws and regulations in effect at the time the Information was created and/or certain good management practices relevant to the subject area. Because every industry and/or workplace presents unique circumstances, the Material does not constitute and is not intended to provide specific advice, assurances, or guarantees concerning any user's compliance with particular regulatory requirements (e.g., OSHA) or other applicable safety and/or health requirements or good management practices. The Material does not constitute training and does not replace the need to properly train all employees nor is the Material a substitute for an assessment of any safety or health hazards present at your facility by a health or safety professional or expert. Users are advised to consult with a legal or other professional advisor concerning specific regulatory compliance requirements applicable to their workplaces and appropriate use of the Material. Users and receivers of the Material are subject in all respects to the terms and conditions set forth [www.grainger.com](http://www.grainger.com), including those provisions relating to limitation of liability. Users and receivers of the Material assume all responsibility and risk arising from any and all use of and/or reliance upon the Material, including any modifications made thereto. W.W. Grainger, Inc. makes no warranty, express or implied, that the Material is current, accurate, appropriate or complete for any particular facility or requirements applicable to a particular facility.